

PROFORMA REGARDING SAFE DRINKING WATER
AND SANITARY CONDITION CERTIFICATE

Letter No.....963.....

Date.....02/6/2026.....

It is certify that an inspection team headed by **Sri Anuj kumar Choubey (Name of Officers with Designation)** From **Quality Manager District Level water Testing Laboratory (NABL) D.W.& S. Division, Garhwa** (Name of Department / office) inspected the School Name – **G.N.Convent School, Purani Bazar, Garhwa, Dist- Garhwa**. Pin – 822114 , Jharkhand on 27.05.2026 (Date) and found that the Dist – Garhwa has safe drinking water facilities for the student and members of– **G.N.Convent School, Purani Bazar, Garhwa ,Dist- Garhwa**. Pin – 822114 staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State / U.T Govt.

The above is valid for a period of **One Year** (2026-27)

Signature with Seal:

Name

: Er. Ajay kr. Singh

Designation

: Executive Engineer

D.W & S. Division Garhwa.

To,

The Principal,

G.N.Convent School, Purani Bazar, Garhwa.

Dist- Garhwa. Pin- 822114, Jharkhand.

District Level Water Testing Laboratory, Garhwa
Drinking Water and Sanitation Division, Garhwa- 822114, Jharkhand
 Email: dlwtlgarhwa@gmail.com

	Test Report Doc No: GRH-DLWTL-QP-4F19 Issue No.: 01 Revision No.: 00 Date: - 01/02/2019	 TC-16455
---	--	--

Report No:		
Issued To:	Name: Ankit Kumar (Je) Address: G.N.Convent School, Purani Bazar, Garhwa.	Date: 28/05/2026 Sample Code:- 27/05/Grh/ Grh/ Grh/02 Sample Received Date:- 27/05/2026
Sample Description/Type	Ground Water	Sample Collected by: _____ Customer: _____
Sample Location	G.N.Convent School, Purani Bazar, Garhwa.	Sample Condition
Date of Sampling	27/05/2026	Temperature
Date of Start of Analysis	27/05/2026	Humidity
Date of Completion Analysis:	28/05/2026	Sampling Procedure
		Sampling is not done by Laboratory


Sl. No.	Tested Parameter	Unit	Results	Method	Specification as per IS 10500:2012 (Second Revision)	
					Acceptable Limit	Permissible Limit (Absence of Alternate source)
1	pH at 25°C	-	6.82	APHA 24 th Ed.2023-4500-H- B (Electrometric method)	6.5 – 8.5	No relaxation
2	Turbidity	NTU	1.0	APHA 24 th Ed.2023-2130 B (Nephelometric method)	1	5
3	Total Alkalinity as CaCO ₃	mg/l	268	APHA 24 th Ed.2023-2320 B (Titration method)	200	600
4	Total Hardness as CaCO ₃	mg/l	284	APHA 24 th Ed.2023-2340 C (EDTA Titration method)	200	600
5	Calcium as (Ca)	mg/l	74.4	APHA 24 th Ed.2023-3500 Ca B (EDTA Titration method)	75	200
6	Magnesium as Mg	mg/l	23.52	APHA 24 th Ed.2023-3500-Mg B (Calculation method)	30	100
7	Chloride as (Cl)	mg/l	28	APHA 24 th Ed.2023-4500-CL Method B (Argentometric Method) 2017	250	1000
8	Fluoride as (F)	Mg/l	0.98	APHA 24 th Ed.2023-4500 F- C (Ion selective electrode method)	1.0	1.5
9	Colour	HU	5	Visual Comparison-2023 APHA 24 th Ed.2023-2120B	5	15
10	Total Dissolved Solid (TDS)	mg/l	534	APHA 24 th Ed.2023-254C	500	2000
11	Odour	Qualitative	Dis-Agreeable	Is 3025 (part-5) :2017		
12	Taste	Qualitative	Dis-Agreeable	Is 3025 (part-8) :2017		

Remarks:

Note:

- The results listed refer only to the tested sample and applicable parameters as received from the customer.
- The report in full or in part shall not be used for advertising or as evidence in any court of law.
- This report cannot be reproduced except when in full, without the written permission of the Lab in-Charge.
- The Sample will be retained in the laboratory for 07 days from the date of issue of test report.
- All disputes are subjected to the Garhwa jurisdiction.
- The laboratory is responsible for all the information given in the report.

Reviewed and Authorised by


 (Anuj Kr. Choubey)

28/05/26
Authorized Signatory

.....End of the report.....